

# HIMACHAL PRADESH UNIVERSITY

Dated 22-7-2020


## TO WHOM IT MAY CONCERN

That the premises of H.P.U. Model School, Summer Hill, Shimla-5, Distt. Shimla was inspected on 22-7-2020 by the Fire Officer with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued in his favour for Two years (i.e. 22-7-2020 to 21-7-2022) subject to fulfillment conditions:

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

  
सहायक सुरक्षा अधिकारी  
Fire Officer  
हि.प्र. विश्वविद्यालय, शिमला - 5  
H.P. University  
Shimla-5

To

The Principal

H.P.U. Model School

Summer Hill, Shimla-5

  
Chairman

H.P. University Model School,  
Summer Hill, Shimla-171005

Principal   
H.P. University Model School  
Summer Hill, Shimla (H.P.)



DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

**NO OBJECTION CERTIFICATE**

**TO WHOM IT MAY CONCERN**

That the premises of H.P. University Modal School Summerhill, Shimla-5 (H.P.) was inspected on 2020-10-13 with reference to his application No. App/08/03/19/8/819 dated 2019-08-03 10:52:24 by the incharge Fire Station FS Tilak Nagar with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence. No Objection Certificate is issued/ renewed for two years w.e.f. 26/10/2020 to 25/10/2022 subject to fulfilment of the following conditions -

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire services.
4. Good House keeping must be maintained within the premises.

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function where temporary structures and Pandals are to be erected.**

*A. Sharma*

[Digitally Signed 26-10-2020 13:38:26]

**Chief Fire Officer.**  
Himachal Pradesh Shimla-2

Place: Shimla

Dated: 2020-10-26